

Instructions

NAI/FPI **♦ IO-**Link *Pressure Transmitter*

8273/8237

Warning: Before installation, commissioning, and operation, ensure that the pressure transmitter is suitable for the application in terms of measuring range, design and environmental conditions. Non-observance can result in serious injury and/or damage to equipment. Intended use: This instrument converts pressure into an electrical signal. The instrument has been designed and built solely for the intended use described here and may only be used accordingly. If the equipment is used in a different manner, the protection provided by the equipment may be impaired and Trafag shall not be liable for any claims at all.

Related documents

Datasheet NAI 8273 FPI 8237 Interface description



www.trafag.com/H73664


IODDs



To download the IODDs for the NAI 8273 and FPI 8237 devices refer to: https://ioddfinder.io-link.com

Type label description (example)


www.trafag.com/H72621 www.trafag.com/H72622



Electrical connections

Type code	8273.XX.XXXX.32	8237.XX.XXXX.35	
Designation	M12x1	M12x1	L+
	4-pole	5-pole	IO-Link
Pin configuration	3 2	5 3 2	C/Q OUT1 Sio Standard I/O
	4-10-3	4	○ I/Q OUT2 SIO Standard I/O
		Pin 5: no function and	_


Load depending on ambient temperature




max. load of each switching output C/Q, I/Q


Connection of loads to switch contacts

(Switching output polarity)



Config. modes of the switching signal channels / switching outputs





For parameterisation details refer to the Interface description www.trafaq.com/H73664